

N61165.AR.005339
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF INITIAL GROUDWATER ASSESSMENT REPORT
RECEIVED 28 MARCH 2001 AND NO FURTHER ACTION (NFA) FOR SITE 43 BUILDING
M82 CNC CHARLESTON SC
04/05/2001
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL



2600 Bull Street
Columbia, SC 29201-1708

5 April 2001

COMMISSIONER:
Douglas E. Bryant

BOARD:
Bradford W. Wyche
Chairman

William M. Hull, Jr., MD
Vice Chairman

Mark B. Kent
Secretary

Howard L. Brilliant, MD

Brian K. Smith

Rodney L. Grandy

Larry R. Chewning, Jr., DMD

DEPARTMENT OF THE NAVY
SOUTHERN DIVISION NAVAL FEC
GABRIEL MAGWOOD
P.O. BOX 190010
N. CHARLESTON SC 29419-9010

Re: Site 43, Building M82
Site Identification # 01538
Initial Ground-Water Assessment Report received 28 March 2001
No Further Action
Charleston County

Dear Mr. Magwood:

The Department has reviewed the referenced assessment report. As submitted, the report documents current and historical efforts to monitor soil and groundwater for hydrocarbon contamination at the subject site. Based on this review, it appears that maximum contaminant levels have not been exceeded in soil and/or groundwater at the site.

Based on the information and analytical data submitted, the Department recognizes that the Department of the Navy has adequately addressed the known environmental contamination identified on the property to date in accordance with the approved scope of work. Consequently, no further investigation is required at this time. Please note, this statement pertains only to the portion of the site addressed in the referenced report and does not apply to other areas of the site and/or any other potential regulatory violations. Furthermore, the Department retains the right to request further investigation if deemed necessary.

The monitoring well(s) may be permanently abandoned by a certified well driller licensed in South Carolina in accordance with the South Carolina Well Standards and Regulations, R.61-71 or properly maintained. Should you choose to abandon the well, please submit a well abandonment record to my attention within 30 days of abandonment. Should you choose to properly maintain the monitoring well, please notify me within 14 days of this correspondence.

Should you have any questions, please contact me at 803-898-3553 (office phone), 803-898-3795 (fax) or bishopma@columb32.dhec.state.sc.us.

Sincerely,

Michael Bishop, Hydrogeologist
Groundwater Quality Section
Bureau of Water

Tom Knight, Manager
Groundwater Quality Section
Bureau of Water

cc: Trident District EQC
Mihir Mehta - SCDHEC BLWM
Brian Crawford, Charleston Naval Complex, 1848 Ave. F, N. Charleston, SC 29405
Technical File